

Off-grid PV system for lighting load of UIET, KUK (Design and estimated cost)

Ashish Dhanowa¹, Vijay Kumar Garg²

¹M.tech-EE, UIET, KUK.

¹+91-9467224055, ashishdhanowa@gmail.com

²Asst. Pro., M.tech-EE dept.UIET, KUK

²+91-9466634299, vijaygarg@gmail.com

Abstract: In India electricity demands increasing very rapidly so load on generation and distribution system. The conventional resources for electricity production like coal, nuclear etc are inefficient to meet the energy demands and also grid is not available at remote places. So we have to increase the use of renewable resources like solar, wind and biomass etc. Off-grid solar PV systems are popular now days and it is best solution for remote area electrification. In this paper a possible design of PV system for lighting load of University Institute of Engineering and Technology, Kurukshetra University, Kurukshetra is suggested. The lighting load is estimated and then other calculations are done.

List of Symbols

W - Watt

kW – Kilowatt

E_L – Estimated load

η_{bo} – Efficiency of balance of system like inverter and wire losses

M_{Loss} – Factor of losses like temperature losses, dust etc

PSH – Peak sun hours

S – Peak solar intensity at earth surface

N_s – Number of module in series

N_p – Number of module in parallel

B_c – Battery bank capacity

B_{req} – Batteries required

B_s – Batteries in series

B_p - Batteries in parallel

P_{inv} – Inverter power

N_{vg} – Number of voltage regulator

1. LIGHTING LOAD ESTIMATION

University Institute of Engineering and Technology (UIET), Kurukshetra University, Kurukshetra build with three floors, garden and parking area which having several tube lights. For this total lights of UIET is counted and wattage of each light is noted than daily hour usage of lights are estimated. The table below shows calculation for load estimation.

Table 1 – Load estimate

| Name of floor | No. of tube | Watts | Hour used/day | Watt hour/day |
|-----------------------|-------------|-------------------|---------------|---------------|
| Ground floor | 383 | 40 | 5 | 76600 |
| 1 st floor | 379 | 40 | 5 | 75800 |
| 2 nd floor | 318 | 40 | 5 | 63600 |
| Grounds and parking | 10 | 40 | 8 | 2000 |
| Total | 1090 | 1090x40 =43600 | | 218000 |

Total lighting load of UIET = 43600 W or 43.6kW.

2. SYSTEM VOLTAGE SELECTION

In off- grid PV system voltage of system is 12V/24V/48V and now days even more higher voltage also selected in very high load system. System voltage selection is based on daily load, so if load is high higher system voltage is selected. Higher system voltage reduces conversion losses of inverter. Here daily load is high so 48vdc system voltage selected.

3. PV PANEL SELECTION

PV panel selection is based on cost, warranty, performance and maintenance. Available area for installation is also considered. High power panel reduces total panel requirement and improve overall system efficiency. Here EmmVee 24V panel is selected which is a 295Wp panel. Panel specification given below.

| | |
|----------------------|-------------|
| Manufacturer/ Brand | EmmVee |
| Peak power | 295 watts |
| Module Efficiency | 14.7% |
| Peak power voltage | 36.51 volts |
| Peak power current | 8.08 amps |
| Open circuit voltage | 44.78 volts |

| | |
|-----------------------|---------------|
| Short circuit current | 8.30 amps |
| Number of cells | 72 cells |
| Max. System voltage | 1000 volts DC |
| Length | 2007 mm |
| Width | 990 mm |
| Depth | 35 mm |
| Weight | 28.5 kg |

4. PV ARRAY SIZE CALCULATIONS

PV array size calculations is somehow depends on the solar irradiance data of the site where this going to be installed. So average solar isolation for the Kurukshetra is given in table below. This is also called average sun hours when peak solar intensity is received (PSH).

Table 2 – Average solar isolation

| MONTHS | 22 Year Average (Source: NASA) kWh/m ² /day |
|----------------|---|
| Jan | 3.58 |
| Feb | 4.38 |
| Mar | 5.59 |
| Apr | 6.10 |
| May | 6.40 |
| June | 6.20 |
| July | 5.50 |
| Aug | 5.14 |
| Sep | 5.23 |
| Oct | 4.71 |
| Nov | 4.01 |
| Dec | 3.36 |
| Annual Average | 5.01 |

Now the PV array size for given system is given as

$$P_{pv} = \frac{E_L}{\eta_{bo} \times M_{Loss} \times PSH} \times S$$

Where

PSH = 5.01 (peak solar hour for UIET, KUK form above table)

M_{Loss} = 83% (module loss factor like manufacturing defect, dust and temperature losses)

η_{bo} = 85%

S = 1 kW/m²

$$P_{pv} = \frac{218}{0.85 \times 0.83 \times 5.01} \times 1 = 61.8 \cong 62 \text{ kw}$$

Number of module in series (N_s)

$$N_s = \frac{V_{system}}{V_{module}} = \frac{48}{24} = 2 \text{ modules}$$

Number of module in parallel (N_p)

$$N_p = \frac{P_{pv}}{N_s \times P_{module}} = \frac{62 \times 1000}{2 \times 295} = 105.08 \cong 106 \text{ modules}$$

$$\text{Total Module} = N_s \times N_p = 2 * 106 = 212 \text{ modules}$$

5. BATTERY BANK CAPACITY CALCULATIONS

Battery bank capacity depends on days of autonomy, depth of discharge. Solar batteries are sized in ampere hour. Here days of autonomy (A_n) taken is 1 (24 hours) and solar batteries now days having 70% to 80% depth of discharge so here 75% DOD is taken. So battery bank capacity (B_c) is calculated as:

$$B_c = \frac{A_n \times E_L}{DOD_{max} \times V_{system} \times B_{Loss}}$$

$$B_c = \frac{1 \times 218 \times 1000}{0.75 \times 48 \times 0.85} \cong 7130 \text{ Ah}$$

The battery here selected is Exide 6LMS which has 150 Ah capacity and having 12v nominal voltage. So the number of batteries (B_{req}) required is

$$B_{req} = \frac{B_c}{B_{selected}} = \frac{7130}{150} \cong 48 \text{ batteries}$$

Number of batteries in series (B_s)

$$B_s = \frac{V_{system}}{V_{battery}} = \frac{48}{12} = 4 \text{ batteries}$$

Number of batteries in parallel (B_p)

$$B_p = \frac{B_{req}}{B_s} = \frac{48}{4} = 12 \text{ batteries}$$

6. INVERTER SIZE CALCULATIONS

The inverter size depends on power drawn by appliances running at same time and surges if motor load is present and also the system expansion in future. So the inverter size is calculated as:

$$P_{inv} = (Tkw + P_{sur}) \times 1.25$$

$$P_{inv} = 43.6 \times 1.25 \cong 55 \text{ KVA}$$

As here no surges or motor load is present in system so P_{sur} is zero.

7. SOLAR REGULATOR OR CHARGE CONTROLLER SIZE CALCULATIONS

The regulator which used in system should having rating which matched to both PV panel and battery and also it is capable to handle current from PV. The size of voltage regulated is calculated as:

$$I_{rated} = N_p \times I_{sc} \times F_{safety}$$

Here F_{safety} is safety factor for system. 1.25 is selected here.

$$I_{rated} = 106 \times 8.30 \times 1.25 = 1099.75 \cong 1100 \text{ A}$$

Here Phocos CML 20A/48vdc solar regulator or charge controller selected

So number of voltage regulator required is given as:

$$N_{vg} = \frac{I_{rated}}{I_{selected}} = \frac{1100}{20} = 55 \text{ voltage regulator}$$

8. AREA FOR INSTALLATION

Total Roof area of UIET = $3400m^2$
 Area of selected panel = $1.9503m^2$
 Total area required for installing solar panel
 $Area = 204 \times 1.9503 = 397.86m^2 = 4282.53ft^2$

9. RESULT TABLE

Table 3 – Result table

| Components | Description | Results |
|-------------------|-------------------|------------------------|
| Load | Total load | 218 kwh/day |
| Pv Array | Total size | 62 kw |
| | In Series | 2 |
| | In parallel | 106 |
| Battery Bank | Total panel | 212 |
| | Capacity | 7130 Ah |
| | In series | 4 |
| | In parallel | 12 |
| Inverter | Total | 48 |
| | Capacity | 55 KVA |
| Charge controller | Capacity | 1100 A |
| | Required number | 55 |
| Area | Total = $3400m^2$ | Required = $397.86m^2$ |

10. COST ESTIMATE OF THE SYSTEM

Table 4 – Cast estimate

| Component and Model | Quantity×Unit price(INR) | Total (INR) |
|--|--------------------------------------|-------------|
| Modules- EmmVee | 212×17000 | 36.04 lakh |
| Batteries- Exide 6LMS | 48×15600 | 7.488 lakh |
| Inverter- STATCON Power Controls Ltd. | 1×7.15 lakh | 7.15 lakh |
| Controller- Phocos CML 20A | 55×3200 | 1.76 lakh |
| BOS (wires, breakers, connectors etc.) | These costs 10 to 20% of system cost | 5.24 lakh |
| Total cost | | 57.68 lakh |

11. GOVERNMENT SUPPORT

Government support is necessary to promote the use of renewable energy resources. The various schemes like JNNSM etc are running by government to support financially

to project developer. Some detail of government scheme is given below.

MNRE capital subsidy scheme

The scheme provides subsidy and interest bearing loan to the solar project under various conditions. Different off-grid solar PV systems having maximum capacity up to of more than 100 kWp (Kilowatt peak) per site are eligible for subsidy schemes. MNRE would provide financial support through a combination of 30 % subsidy and/or 5% interest bearing loans to the eligible solar grid or off grid projects. By March 2013, the benchmark price for photovoltaic systems with battery back-up support was Rs.200/- per Wp and Rs. 130/- per Wp for without storage battery. For financial year 2013-14, the benchmark price for PV systems with battery back-up support was Rs.170/- per Wp and Rs. 90/- per Wp for without storage battery. These rates are for off grid solar power plant of total installed capacity from 10 KWp -100 KWp.

For special category states like North East, Sikkim, J&K, Himachal Pradesh and Uttarakhand Capital subsidy of 90% of the benchmark cost is available. In addition, for standalone rural solar power plants with both technologies i.e. solar PV and solar thermal in remote and difficult areas such as Lakshadweep, Andaman & Nicobar Islands, and districts on India's international borders capital subsidy up to 60% of benchmark price is exclusively available. The release of funds under MNRE capital subsidy scheme is by two installments of 70% on sanction and 30% on completion. It means that the solar project can be started after the receipt of capital subsidy and necessary approval from MNRE and the state nodal agency.

12. CONCLUSIONS

In this paper, the lighting load of UIET is estimated which is 218 kwh/day. PV array size and other components sizes are calculated according to load demand. As UIET collage have grid connection so no back-up generator required. This possible design of PV system is to reduce the power requirement of UIET from Grid and sifting lighting load on solar power. For this 48vdc system 212 panels, 48 batteries and 7 voltage regulator required. The balance of system like wires, connectors etc are required.

REFERENCES

- [1]. Solar power generation by PV (Photovoltaic) technology: a review by G.K. Singh, Dept. of electrical engineering, IIT, Roorkee, india. ELSEVIER-2013
- [2]. Modeling of Photovoltaic power plant by zakariaanwarzakaria, bai-chaochen from wuhan university/school of Electrical Engg., wuhan, china and Mohammed Osman Hassan from Huazhong university of science & technology/school of electrical engg, wuhan, china.
- [3]. Design of an off grid photovoltaic system: A case study of government technical collage, wudil, kano state by Ishaq M, Ibrahim U Haruna and AbubakarHarnua from Bayero University, Kano, Nigeria. IJSTR volume 2, issue 12, dec-2013

-
- [4]. Pilot Centralized Solar Power Station in Remote Village, Rompin, Pahang by Iszuan Shah Syed Ismail, Azmi Omar, and Hamdan Hassan at National Power and Energy Conference (PECon) 2003 Proceedings, Bangi, Malaysia
 - [5]. Study of a solar PV-diesel-battery hybrid power system for a remotely located population near Rafha, Saudi Arabia by ShafiqurRehman and Luai M. AL-Hadrami, center of engineering research, research institute, King Fahd University of Petroleum & Minerals, KFUPM, Dhahran, Saudi Arabia. ELSEVIER-2010
 - [6]. Renewable energy technology in India: panacea for sustainable development by U.Anitha, U.Vanitha, U.Nivedha and S.Usha Rani in IEEE-ICAESM-2012
 - [7]. Official website of MNRE, India.
 - [8]. EmvEE ES 275-295 P72 PV modules datasheet
 - [9]. www.wikipedia.com/solar
 - [10]. www.nrel.gov/gis/solar.html
 - [11]. Official web site of MNRE - www.mnre.gov.in
 - [12]. NASA Surface meteorology and Solar Energy Location website: <https://eosweb.larc.nasa.gov/cgi-bin/sse/grid.cgi?email=skip@larc.nasa.gov>